

NORTH COUNTY FIRE PROTECTION DISTRICT

330 S. Main Avenue • Fallbrook, California 92028-2938 • (760) 723-2005 • Fax (760) 723-2072 • www.ncfireprotectiondistrict.org

BOARD OF DIRECTORS

RUTH HARRIS
WAYNE HOOPER
KENNETH E. MUNSON, President
PAUL SCHADEN
KATHLEEN THUNER, Vice President

WILLIAM R. METCALF - Fire Chief/CEO
wmetcalf@ncfire.org
ROBERT H. JAMES - Counsel
LOREN A. STEPHEN-PORTER - Board Secretary
lstephen@ncfire.org

June 12, 2017


County of San Diego
Planning & Development Services
5510 Overland Ave., Suite 321
San Diego, CA 92123

Ref: **TPM 21222**
106-410-43 plans dated 5/31/17

Please note the following comments pertaining to TPM 21222.

The fire access road and driveways shall be paved to minimum a 16ft. and shall be designed and maintained to support the imposed loads of fire apparatus (not less than 75,000 lbs.). If more than two structures are served by the access road, it will need to be improved and paved to 20 ft. Where required, in order to meet storm water requirements, a pervious asphalt or concrete surface will be acceptable.

Sincerely,



Patty Koch, Fire Marshal
760 723-2040



PROUDLY SERVING THE COMMUNITIES OF FALLBROOK, BONSALE AND RAINBOW

North County Fire Protection District
330 S. Main Ave
Fallbrook, Ca 92028
Inspection Billing Statement

Responsible Party

FALLBROOK, CA 92028

Inspection Performed At

Beebe property
893 PALOMINO RD
Fallbrook, CA 92028

Inspection Type	Date	Fee/Fine
111 PLAN REVIEW- Improvement Plans (PRD) 1.12	06/12/2017	\$210.00
Violations Discovered:		
		<hr/>
		\$210.00
		CASH
	CHECK NUMBER	CHECK
	CREDIT CARD AUTHORIZATION NUMBER	
RECEIVED FROM		BALANCE DUE
<hr/>		PAID IN FULL